


# **Cowichan Lake Weir Lake Pumping and Coldwater Release Options**

# Background

In 2006, NHC completed a conceptual or feasibility-level study examining the potential for a lake pumping station located at the current weir.

A link to a digital PDF copy will be provided to the Board for distribution.



# Feasibility Design Options

2 options were examined in the feasibility study:

**Option A** – Lake pumping with a cold water supply pipeline

**Option B** – Lake pumping with a surface water supply

Both options were constructed on the left bank of the existing weir.

# Design Criteria

The study used the conditions:

- Minimum lake elevation                      161.26 m
- Weir crest elevation                            162.37 m
- Minimum flow                                    7 m<sup>3</sup>/s

Designed to operate infrequently – every 3 to 5 years continuously for up to 100 days.

# Design Criteria


- Minimize civil works and off site impacts
- Minimize potential for fish entrainment impacts
- Safety for boaters and recreational use
- Flexible delivery of flows using up to 5 mixer-type pumps
- Incorporation of a 2.1 m dia. deepwater supply pipeline and surface water intakes
- Erosion protection installed downstream

# Data Available at the time...



- Flow and water level data
- Climate data
- Limited bathymetric data
- Limited limnological data
- Limited design data....

Hmmmm?

# Feasibility Study Project Location




# Option A – Deepwater Pipeline and Pump





- NOTES:**
1. ALL DIMENSIONS ARE GIVEN IN PROTOTYPE MILLIMETERS.
  2. ALL ELEVATIONS ARE GIVEN IN PROTOTYPE METERS.
  3. DOWNSTREAM CAISSON TO BE CUT TO GRADE FOLLOWING CONSTRUCTION.
  4. SUPPLY PIPE LOCATION TO BE DETERMINED.



# Option A – Deepwater Pipeline and Pump



# Option B – Surface Water Pump



**NOTES:**

1. ALL DIMENSIONS ARE GIVEN IN PROTOTYPE MILLIMETERS.
2. ALL ELEVATIONS ARE GIVEN IN PROTOTYPE METERS.
3. DOWNSTREAM CAISSON TO BE CUT TO GRADE FOLLOWING CONSTRUCTION.

# Option A Costs

	Item	Unit	Rate	Quantity	Cost
1	Installation of sheet pile caisson	m <sup>2</sup>	\$270	500	\$135,000
2	Demolition of existing weir	LS			\$50,000
3	Excavation of caisson	m <sup>3</sup>	\$50	500	\$25,000
4	Metalwork	kg	\$5	40,000	\$200,000
5	Sluice Gates	ea.	\$20,000	5	\$100,000
6	HDPE pipeline	m	\$1,250	1,000	\$1,250,000
7	Structural concrete	m <sup>3</sup>	\$1,200	904	\$1,084,800
8	Riprap	m <sup>3</sup>	\$100	100	\$10,000
9	Mixer Pumps and Support	ea.	\$51,000	5	\$255,000
	Subtotal				\$3,109,800
	Detail Design and Engineering (7%)				\$217,686
	Construction Supervision and Environmental Mitigation (5%)				\$203,180
	Project Contingency (15%)				\$466,470
	<b>Total Project Estimate</b>				<b>\$3,949,446</b>

# Option B Costs

	<b>Item</b>	<b>Unit</b>	<b>Rate</b>	<b>Quantity</b>	<b>Cost</b>
1	Installation of sheet pile caisson	m <sup>2</sup>	\$270	500	\$135,000
2	Demolition of existing weir	LS			\$50,000
3	Excavation of caisson	m <sup>3</sup>	\$50	500	\$25,000
4	Metalwork	kg	\$5	40,000	\$200,000
5	Sluice Gates	ea.	\$20,000	5	\$100,000
6	Structural concrete	m <sup>3</sup>	\$1,200	904	\$1,084,800
7	Riprap	m <sup>3</sup>	\$100	100	\$10,000
8	Mixer Pumps and Support	ea.	\$51,000	5	\$255,000
	Subtotal				\$1,859,800
	Detail Design and Engineering (7%)				\$130,186
	Construction Supervision and Environmental Mitigation (5%)				\$92,990
	Project Contingency (15%)				\$278,970
	<b>Total Project Estimate</b>				<b>\$2,361,946</b>

# Operational Costs

- Use of up to 5 – 37 kW 600 V Flygt mixer pumps
- \$500 per day at current BCH rates
- \$7,000 per month for back-up diesel generators
- \$50,000 per year for operations and maintenance (mobilization – removal – repairs – storage)

# Data Gaps Identified

- Temperature monitoring and assessment of the lake outlet and upper Cowichan River
- Additional bathymetric surveys upstream and downstream of the weir
- Limnological monitoring and depth-integrated sampling in Cowichan Lake
- Assess potential fish entrainment and mitigation
- Assess geotechnical conditions and preliminary design requirements

# Preliminary Design Questions

- Is 20 m depth enough for 10°C water?
- Value engineering and design to avoid a large costly sump?
- New low head pumping technology?
- Cost-benefit of pipeline length relative to depth and ambient hypolimnetic temperature?
- What downstream aquatic benefits can be realized from a cold water supply on Cowichan Lake?

# Limnology




Figure 7. Seasonal water temperatures measured at 1m to 5 m metre intervals in Cowichan Lake in the main basin (Site E217509).



# Mixer Pump Design Curves




Figure 3-1: Total Dynamic Head Rating Curve for Flygt Model 4680 with a 17 Degree Impeller



# Downstream Aquatic Benefits - Example


- Effects of potential climate change adaptation infrastructure on Sproat and Great Central Lake
- Effects of high water temperatures on Sockeye salmon migration delay and mortality
- Conducted temperature modelling and conceptual design of CCA Infrastructure to cool lower Somass, Sproat and Stamp Rivers

# Conceptual Options

Need to supply between 2 to 10 m<sup>3</sup>/s of water from depth out of Stamp and Sproat Lakes:


1. “Push” cold water out of lake with dam
2. Pump cold water from lake bottom
3. Epilimnetic Curtain system
4. Hypolimnetic Air-Lift Pump
5. Low head pump system – mixer or screw pump

# Thermal Curtain Option



ELEVATION VIEW  
LOOKING UPSTREAM

# Thermal Curtain Option





# Gravity Pipeline Option

- Utilize existing dams and weirs to provide “energy” to drive water through deep water pipelines
- Require significant capital investment
- No change to water levels during summer
- Known technology and materials
- Need enough energy – water elevation or head – to overcome energy losses and velocity head



# Temperature Modelling

- Using 2 years of data, a hydraulic temperature model of the system was constructed for the entire system
- The model uses flow and meteorological data to estimate river temperatures at downstream locations on an hourly time step
- Preliminary Sockeye migration data indicated a high correlation to time-of-day and water temperature changes

# Data – lots of it!



SiteName GCL Dam






# Data Results – Temperatures

- Data indicates that air temperatures dictate daily and seasonal water temperatures
- Water temperatures vary greatly over a 24 h period
- Shallow water outlets and stratified lake conditions lead to increased temperatures

# Temperature Modelling

**Sproat River Water Temperatures near Stamp**  
Hourly Values - 13AUG2008 to 21AUG2008




# River Temperature Mitigation


A total of 4 test conditions were examined against the base case model:

1. Coldwater release from Sproat Outlet
2. 5 m<sup>3</sup>/s coldwater releases from GCL Dam
3. 10 m<sup>3</sup>/s coldwater releases from GCL Dam
4. Flow control and coldwater release from both Sproat and GCL (coldwater only)


# Status Quo



# Full Implementation of CCAI




# Scenario Results – Hottest Day



# Coldwater in Sproat Lake and GCL

- Cold isothermal water lies below the thermocline in GCL and Sproat Lakes
- Stratification occurs May through late October every year



# Proposed CWRF Infrastructure

## Great Central Lake CWRF:

- 2 - 1000 m long 1.6 m dia. HPDE pipelines
- 30 m depth to 6°C lake water
- Use existing dam to provide 4 m head to drive 11 m<sup>3</sup>/s
- Use existing fishway for returning adult salmon at weir
- Class D costs: \$5.0M - \$5.5M



# GCL Outlet Weir and Pipeline




# Proposed Pilot CWRF Infrastructure


## Sproat Lake CWRF:

- 5 m<sup>3</sup>/s Hypolimnetic air lift pump
- 25 m depth to 6°C lake water
- 700 m floating pipeline
- No change in existing lake levels
- No modifications to lake outlet
- Class D costs: \$0.8M – \$1.2M


# Sproat Lake Air Lift Pipeline



# Air Lift Pump Technology



# Sproat Lake CWRF – Conceptual Costs



NOT FOR CONSTRUCTION

No.	REVISIONS	DATE	DESIGNER	BMC P.E.C.	PROJECT NUMBER	DRAWING SCALE	DATE	PROJECT NUMBER	DATE	PROJECT NUMBER	DATE	PROJECT NUMBER	DATE
	DESCRIPTION												

Northwest Hydro-Electric Consultants Ltd  
 25 Dundas Place  
 North Vancouver, B.C. Canada V1M 3G3  
 Office: (604) 963-9111 Fax: (604) 960-8284

Sheet Reference Number

# Summary

- A coldwater release facility (CWRF) is conceptually viable at both Sproat Lake and GCL
- Existing infrastructure and access are positive aspects
- Detailed engineering and analysis of options would be required to prove concept to detailed levels

# Questions?

Thanks for the opportunity to speak with you this morning. If you have any questions later, please feel free to contact me:

Barry Chilibeck

Northwest Hydraulic Consultants

(604) 980-6011

[bchilibeck@nhcweb.com](mailto:bchilibeck@nhcweb.com)